

Choudwar - 754071 P.O. Kapaleswar Dist Cuttack Odisha, India

TEL +91 671 2494241 +91 671 2494245 FAX +91 671 2494314

choudwar@imfa.in

Corporate Office

IMFA Building Bhubaneswar -751010 Odisha, India

TEL +91 674 3051000 +91 674 2580100 FAX +91 674 2580020 +91 674 2580145

mail@imfa.in

www.imfa.in

Ref: PP/ENV/14/ Date: 19.05.2014

Mr. S.Kerketta, Joint Director (S) Ministry of Environment & Forests, Eastern Regional Office, A/3, Chandrasekharpur, Bhubaneswar – 751023.

Sub: Half yearly compliance report of 2X60 MW Power Plant (from October'12 to March'13).

Ref: 1. Clause no. 3 (xxii), of Environmental Clearance Letter

No. J-13011/19/2008-IA.II(T) dt 09.05.2008

2. Letter from MoEF, Eastern Regional Office dt 09.10.2007

Dear Sir,

Reference above, we are enclosing herewith half yearly compliance report (Oct'13 to March'14) in Annexure – I and soft copy of the same in CD for your needful.

Thanking you, Yours faithfully,

for INDIAN METALS & FERRO ALLOYS LTD.

(B. Mohaptra)

Vice President (Operations) - Power

Encl: As above.

cc to : Member Secretary,

State Pollution Control Board, Orissa,

Paribesh Bhavan,

A/118, Nilakanthanagar, Unit – VIII,

Bhubaneswar – 751012.

cc to: Regional Officer,

State Pollution Control Board, Orissa,

586, Suryavihar, Link Road.

Cuttack - 753012.

	COMPLIANCE TO CONDITIONS OF MOER CALEAR	RENCE FOR 2x60 MW POWER PROJECT				
SI.No.	CONDITION	COMPLIANCE STATUS				
I)	The total land requirement for the project shall be restricted to 60.00 acres.	60 acres land ,belonging to UPL is already available. The relevant document has been sent to SPCB under the cover of letter no. SVP(O)/SPCB/07 Dt.30.08.07 as required while applying for NOC.				
ii)	Sulphur and ash contents in the coal to be used in the project shall not exceed 0.4 % and 50% respectively.	Use of coal with sulfhur & ash content limited to 0.4% & 50% respectively, has been considered for design of boiler and will be ensured during operation.				
iii)	Two stacks of 48 m height each have been proposed. Continuous on line monitoring equipments for SOx, NOx and Particulate will be provided. Exit velocity of flue gases shall not be less than 15 m/sec. Possibility of having a bi-flue stack may be explored and the stack height may be finalized in consultation with CPCB/SPCB.	been fitted to each stack. Exit velocity of flue gas, more than 15m/sec, has been considered in equipment designing and will be ensured				
	High efficiency Electrostatic Precipitator (ESPs) shall be installed to ensure that particulate emission does not exceed 50 mg/Nm³.	Installation of High efficiency Electrostatic Precipitator (ESPs) have been completed. It will be ensured during operation that particulate emission will not exceed 50 mg/Nm³.				
	CFBC boiler with lime injection with efficiency of sulphur removal upto 90% shall be provided.	Lime handling system has been deployed with injection system with sulphur removal upto 90%.				
vi)	Dry low Nox burners shall be provided.	The CFBC boilers do not envisage any coal burners. Due to the state of the art technology the furnace temp is maintained low and hence the NO_{x} emission is very low.				
vii)	Adequate dust extraction system such as cyclones/ bag filters and water spray system in dusty areas such as in coal handling and ash handling points, transfer areas and other vulnerable dusty areas shall be provided.	provided at coal and ash handling system. Also water spray/sprinkling				
	Fly ash shall be collected in dry form and its 100 % utilization shall be achieved from day one.	Dry dense phase pneumatic ash handling system and ash silo have been deployed and 100% ash utilisation will be ensured.				
ix)	No ash Dyke shall be created as part of this project; however, an area not exceeding one acre shall be earmarked for ash handling.	ash dyke will be created.				
x)	Closed cycle cooling system with cooling towers shall be provided. The effluent shall be treated as per the prescribed norms.	Closed cycle cooling system with cooling towers have been installed The effluent will be treated as per the prescribed norm during operation of the plant.				

SI.No.	CONDITION Half yrly co	mpl COMPLIANCE STATUS
xi)	The treated effluents conforming to the prescribed standards shall be recirculated and reused within the plant. There shall be no discharge outside the plant boundary except during monsoon for storm water. Arrangements shall be made that effluents and storm water do not get mixed.	deployed. Treated effluent conforming to prescribed standard are being re-circulated & reused inside the plant.
	A sewage treatment plant shall be provided and the treated sewage shall be used for raising greenbelt/plantation.	The sewage water is soaked through soak pit
	Rainwater harvesting should be adopted. Central Groundwater Authority/ Board shall be consulted for finalization of appropriate rainwater harvesting technology within a period of three months from the date of clearance and details shall be furnished.	
xiv)	Adequate safety measures shall be provided in the plant area to check/minimize spontaneous fires in coal yard, especially during summer season. Copy of the these measures with full details along with location plant layout shall be submitted to the Ministry as well as to the Regional Office of the Ministry at Bhubaneswar.	fire hydrant points surrounding the coal yard has been deployed. Drawing no. SGC-BEV-IMF-0103 showing all detail has been
	Regular monitoring of ground water in and around the plant area shall be carried out, records maintained and periodic reports shall be furnished to the Regional Office of this Ministry.	
,	A green belt of adequate width and density shall be developed around the plant periphery covering about 1/3 rd of the project area preferably with local species.	
xvii)	First aid and sanitation arrangements shall be made for the drivers and other contract workers during construction phase.	One safety center along with first aid facility and one ambulance was provided. First aid boxes were provided at all major work places. Separate toilets for ladies and gents were provided.
xviii)	Leq of Noise levels emanating from gas and steam turbines shall be limited to 75 dBA. For people working in the high noise area, requisite personal protective equipment like earplugs/ear muffs etc. shall be provided. Workers engaged in noisy areas such as steam & gas turbines, air compressors etc shall be periodically examined to maintain audiometric record and for treatment for any hearing loss including shifting to non noisy/less noisy areas.	have been provided to reduce the noise level. In addition to the above PPEs had been provided to the individuals. Periodic medical examination for individuals will be conducted.

SI.No.	CONDITION	Half yrly co	compl COMPLIANCE STATUS
xix)	Regular monitoring of ground level concentration of SO ₂ : RSPM shall be carried out in the impact zone and record at any stage these levels are found to exceed the processary control measures shall be provided immediation of the monitoring stations and frequency of mondecided in consultation with SPCB. Periodic reports shall be provided in the Regional Office of this Ministry	rds maintained. rescribed limits, nediately. The nitoring shall be	its, he be
xx)	The project proponent shall advertise at least two loc widely circulated in the region around the project, one of vernacular language of the locality concerned and within the date of this clearance letter, informing that the praccorded environmental clearance and copies of clea available with the State Pollution Control Board / Com also be seen at the website of the Ministry of Environmental ://envfor.nic.in.	them shall be in n seven days of oject has been rance letter are mittee and may	of en are lay
	A separate environment management cell with qualifie set up for implementation of the stipulated environment		be Separate environment management cell with qualified staff has been set up and functioning.
xxii)	Half yearly report on the status of implementation of conditions and environmental safeguards shall be suministry/ Regional Office/CPCB/SPCB.		
xxiii)	Regional Office of the Ministry of Environment & For Bhubaneswar will monitor the implementation of conditions. A complete set of documents including Impact Assessment Report and Environment Managen with the additional information submitted from time to forwarded to the Regional Office for their use during more	the stipulated Environmental nent Plan along time shall be	ed tal ng
xxiv)		se cost shall be marked for the erted for other	ner .

SI.No.	CONDITION	Half yrly compl	COMPLIANCE STATUS	
xxv)	The project authorities shall inform the Regional Office Ministry regarding the date of financial closure and final project by the concerned authorities and the dates of development work and commissioning of plant.	approval of the contract of start of land commission obtained.	for supply of equipment along with	erection and already been
xxvi)	Full cooperation shall be extended to the Scientists/Of Ministry / Regional Office of the Ministry at Bhubaneswar SPCB who would be monitoring the compliance of enviro	r /the CPCB/the	omplied.	
xxvii)	The project proponent shall submit six monthly report implementation of the stipulated environmental safeguard its regional office, Central Pollution Control Board & Control Board. The porject porponent shall upload compliance of EC conditions on their website and up periodically and simultaneously send the same by e-mail	ds to the MoEF, State Pollution the status of odate the same	omplied.	
xxviii)	The project proponent will upload the compliance status is and update the same from time to time at least six Criteria pollutants levels such as SOx, NOx, SPM, RSPM ambient air) shall be uploaded on their web site and also the main gate of Power Plant.	monthly basis. Display of M (from stack &		

Monitoring data

AMBIENT AIR QUALITY & STACK EMISSION DATA OF 120MW (OCTOBER' 2013 –MARCH' '2014) Near ETP area Near 120MW Main gate Stack emission (PM)

		Near E I	Parea		Nea	ar 1∠UW	vv iviain	gate	Stack em	iission (PIVI)
Month/week	PM10	SO2	NO2	PM2.5	PM10	SO2	NO2	PM2.5	Boiler # 7	Boiler #8
Oct' 1st week	90	8.9	14.2		99	10.2	13.5			
2 nd week	98	8.7	12.5	52	99	8.5	15.1			
3 rd week	47	7.8	11.6		80	8.1	12.8		41	
4 th week	97	7.3	12.2		94	8.5	12.9			
Nov 1st week	90	7.2	14.8		106	7.4	14.4	66		
2 nd week	122	8.6	15.6		93	7.1	14.1			
3 rd week	83	7.2	13.8		85	6.9	14.2			
4 th week	105	11	16.5		92	7.8	12.6		31	
Dec 1st week	99	8	14.9		100	7.8	13.2		23	
2 nd week	151	8.4	15.2	75	102	7.9	13.8		18	
3 rd week	99	7.8	11.9		104	11.7	14.1			
4 th week	101	8.3	13.6		100	8.1	13.7		19	
Jan 1st week	101	8.2	14.1		120	10.5	13.4	63		33
2 nd week	97	8.2	12.8		94	8.5	11.1			
3 rd week	105	12.3	14.1		100	8.3	14.9			
4 th week	95	8.4	11.5		88	8.4	12.1			41
Feb 1st week	112	10.6	14.9		118	8.5	12.8			24
2 nd week	96	11.8	14.2	55	85	7.2	12.9		15	
3 rd week	94	11.8	13.5		85	7.2	11.7			
4 th week	88	7.5	14.7		114	9	14.9		20	
Mar 1 st week	102	9.8	12.5		68	7.1	11.9			
2 nd week	80	8.5	12.3		57	7.6	10.8		12	
3 rd week	118	8.1	13.5		90	9.4	14.2	51		
4 th week	100	8.4	13.2		112	8	14.1		21	

Env expenditure, CSR, Plantation

Period	Expenditure incurred on environmental management	Plantation, green belt development	CSR activities undertaken
October'13 to March'14	Operation – Rs.1832968/- Maintenance – Nil	Dec - Nil	Six nos. bore-well dug in ward no. 7,8,11 & 12. of Choudward Municipality. Two nos. toilet constructed in Netaji Primary school and Virat Cuttack Primary school of ward no. 10 & 11 of Choudward
	Total – Rs.1832968/-	Feb - Nil	Municipality. 30 girls & ladies were sponsored for tailoring training at Apparel training and design center (ATDC, Choudwar under Ministry of Textile, Govt. of India). One health camp was organised at Agrahat GP. Two nos. steel almirah was donated to Harihar Juva Parishad for storing of library books.